30847

```
#ifndef _VARIAVEIS_H
#define _VARIAVEIS_H

#define NETWORK_CLIENT "cmpc-smartvac"     //nome da rede wifi do cliente

#define PASSW "Procurar_no_gerenciador"  // network password  //senha do wifi di cliente

#define MDASH_APP_NAME "CMPC_30847"    //nome de usuario do madash para esse equipamento

#define DEVICE_PASSWORD "Procurar_device"   //senha do mdash

#define VOLT_CAL    53 //calibracao do sensor de tensao

#define CURRENT_CAL  6.5 //calibracao do sensor de corrente

#define PIN_CURRENT 39  //pino para a leitura de corrente

#define PIN_TEMPE  14   //pino para a leitura temperatura

#define PIN_VOLTAGE 34  //pino para a leitura da tensao  PIN_VOLTAGE

#define EQUIPAMENT_TAG "30847"  //tag do equipamento, deve ser fornecido pelo spo
EQUIPAMENT_TAG

#define EQUIPAMENT_TOPIC "v4/matr0449"  //topico de envio, fornecido pelo spo
EQUIPAMENT_TOPIC

#define INS_SENSOR "s8841"  //endereco sensor de insuflamento

#define RET_SENSOR "s8840"  //endereco sensor de retorno

#define SUC_SENSOR "s8844"  //endereco sensor de sucção

#define LL_SENSOR "s8842"   //endereco sensor de linha de liquido
```

```
#define EXT_SENSOR "s8843"  //endereco sensor de externa

#define VOLT_SENSOR "s8839" //endereco sensor de tensao

#define CURR_SENSOR "s8838" //endereco sensor de corrente

//kit 45
#define SENS_TEMP_RET {0x28, 0x85, 0x01, 0x95, 0xF0, 0x01, 0x3C, 0xE6}  //endereço para a leitura do sensor de temperatura de retorno

#define SENS_TEMP_INSU {0x28, 0x5C, 0x7F, 0x95, 0xF0, 0x01, 0x3C, 0x7B}  //endereço para a leitura do sensor de temperatura de insuflamento

#define SENS_TEMP_LL {0x28, 0xE1, 0xEE, 0x95, 0xF0, 0x01, 0x3C, 0x4C}

#define SENS_TEMP_SUC {0x28, 0x09, 0x0E, 0x95, 0xF0, 0x01, 0x3C, 0x1E}  //endereço para a leitura do sensor de temperatura de sucção

#define SENS_TEMP_EXT {0x28, 0xE5, 0xEE, 0x95, 0xF0, 0x01, 0x3C, 0x90}  //endereço para a leitura do sensor de temperatura de externa

#endif
```

Revision #1
Created 15 September 2023 12:23:27 by Patrick Leal
Updated 15 September 2023 12:23:42 by Patrick Leal