32615

```
#ifndef _VARIAVEIS_H
#define _VARIAVEIS_H

#define NETWORK_CLIENT "cmpc-smartvac"     //nome da rede wifi do cliente

#define PASSW "Procurar_no_gerenciador"  // network password  //senha do wifi di cliente

#define MDASH_APP_NAME "CMPC_32615"    //nome de usuario do madash para esse equipamento

#define DEVICE_PASSWORD "Procurar_no_mdash"   //senha do mdash

#define VOLT_CAL  50 //calibracao do sensor de tensao

#define CURRENT_CAL 18.7 //calibracao do sensor de corrente

#define PIN_CURRENT 39  //pino para a leitura de corrente

#define PIN_TEMPE  14   //pino para a leitura temperatura

#define PIN_VOLTAGE 34  //pino para a leitura da tensao  PIN_VOLTAGE

#define EQUIPAMENT_TAG "32615"  //tag do equipamento, deve ser fornecido pelo spo
EQUIPAMENT_TAG

#define EQUIPAMENT_TOPIC "v4/matr0456"  //topico de envio, fornecido pelo spo
EQUIPAMENT_TOPIC

#define INS_SENSOR "s8958"  //endereco sensor de insuflamento

#define RET_SENSOR "s8957"  //endereco sensor de retorno

#define SUC_SENSOR "s8961"  //endereco sensor de sucção

#define LL_SENSOR "s8959"   //endereco sensor de linha de liquido
```

```
#define EXT_SENSOR "s8960"  //endereco sensor de externa

#define VOLT_SENSOR "s8956" //endereco sensor de tensao

#define CURR_SENSOR "s8955" //endereco sensor de corrente

// SEM DADOS DE QUAL KIT ESTÁ NESSE EQUIP.

#define SENS_TEMP_RET {00000000000000000000000000}  //endereço para a leitura do sensor de temperatura de retorno

#define SENS_TEMP_INSU {00000000000000000000000000000000}  //endereço para a leitura do sensor de temperatura de insuflamento

#define SENS_TEMP_LL {00000000000000000000000000000000000}

#define SENS_TEMP_SUC {00000000000000000000000000000}  //endereço para a leitura do sensor de temperatura de sucção

#define SENS_TEMP_EXT {00000000000000000000000000000}  //endereço para a leitura do sensor de temperatura de externa



#endif
```

Revision #1
Created 15 September 2023 12:02:21 by Patrick Leal
Updated 15 September 2023 12:02:41 by Patrick Leal