9504

```
#ifndef _ENV_H
#define _ENV_H

#define NETWORK_CLIENT "SmartVac Telemetria"

#define PASSW  "xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx" procurar no gerenciador

#define VOLT_CAL  106.63 //calibracao do sensor de tensao

#define VOLT_CAL_S  107.23 //calibracao do sensor de tensao

#define VOLT_CAL_TT  35.52 //calibracao do sensor de tensao

#define CURRENT_CAL  12.17 //calibracao do sensor de corrente

#define CURRENT_CAL_S 12.41  //calibracao do sensor de corrente

#define CURRENT_CAL_TT  11.84 //calibracao do sensor de corrente

#define PIN_CURRENT  39 //pino para a leitura de corrente

#define PIN_CURRENT_S 33  //pino para a leitura de corrente

#define PIN_CURRENT_TT 35   //pino para a leitura de corrente

#define PIN_TEMPE 16    //pino para a leitura temperatura  D5 no hard

#define PIN_VOLTAGE 32  //pino para a leitura da tensao  PIN_VOLTAGE

#define PIN_VOLTAGE_S  34 //pino para a leitura da tensao  PIN_VOLTAGE

#define PIN_VOLTAGE_TT  36 //pino para a leitura da tensao  PIN_VOLTAGE

#define EQUIPAMENT_TAG "9504"  //tag do equipamento, deve ser fornecido pelo spo
EQUIPAMENT_TAG
```

```
#define EQUIPAMENT_TOPIC "v4/matr0547"  //topico de envio, fornecido pelo spo
EQUIPAMENT_TOPIC

#define INS_SENSOR "s91489"  //endereco sensor de insuflamento

#define RET_SENSOR "s91490"  //endereco sensor de retorno

#define SUC_SENSOR "s91491"  //endereco sensor de sucção

#define LL_SENSOR "s91492"   //endereco sensor de linha de liquido

//#define EXT_SENSOR "sTesteExt"  //endereco sensor de externa

#define ENT_CONDES "s91506"  //endereco sensor de externa

#define SAD_CONDES "xxxxxx"  //

#define VOLT_SENSOR_R "s91493" //endereco sensor de tensao

#define VOLT_SENSOR_S "s91494" //endereco sensor de tensao

#define VOLT_SENSOR_TT "s91495" //endereco sensor de tensao

#define CURR_SENSOR_R "s91496" //endereco sensor de corrente

#define CURR_SENSOR_S "s91497" //endereco sensor de corrente

#define CURR_SENSOR_TT "s91498" //endereco sensor de corrente

#define BAT_SENSOR_INS "s91502" //endereco sensor de corrente

#define BAT_SENSOR_RET "s91503" //endereco sensor de corrente

#define BAT_SENSOR_SUC "s91504" //endereco sensor de corrente

#define BAT_SENSOR_LL "s91505" //endereco sensor de corrente

#define VIBR_SENSOR_X_SUC "s91499" //endereco sensor de corrente

#define VIBR_SENSOR_Y_SUC "s91500" //endereco sensor de corrente
```

```
#define VIBR_SENSOR_Z_SUC "s91501" //endereco sensor de corrente

#define SENS_TEMP_RET "bc:57:29:0e:2e:db" //entrada de água

#define SENS_TEMP_INSU "bc:57:29:0e:2e:e0"  // saída de água

#define SENS_TEMP_LL "bc:57:29:0e:19:cf" //descarga ckt 1

#define SENS_TEMP_SUC "bc:57:29:0e:19:76"  //sucção ckt 1

#define SENS_TEMP_ENT_CONDENS "bc:57:29:0e:2e:b3"  //externa

#define SENS_TEMP_SAD_CONDENS "bc:57:29:0e:xx:xx"  //endereço para a leitura do sensor de saida da condensação

#endif
```

Revision #1
Created 9 October 2024 12:25:50 by Patrick Leal
Updated 9 October 2024 12:26:35 by Patrick Leal